

Message

From: Cook, David [DAVID.COOK@Illinois.gov]
Sent: 6/19/2019 8:26:49 PM
To: Deltoral, Miguel [deltoral.miguel@epa.gov]
Subject: FW: University Park Data
Attachments: ATT00001.txt; Xerox Scan_06192019152453.pdf

Brad Frost and Kim Biggs are working on a summary of public outreach. I'll forward to you when available.


From: Cook, David
Sent: Wednesday, June 19, 2019 3:25 PM
To: Frost, Brad <Brad.Frost@Illinois.gov>; Biggs, Kim <Kim.Biggs@Illinois.gov>; Vance, Steve <STEVE.VANCE@Illinois.gov>; Cobb, Rick <RICK.COBB@Illinois.gov>; Sofat, Sanjay <Sanjay.Sofat@Illinois.gov>; Reed, Mary F <MARY.F.REED@Illinois.gov>; Olson, Joanne <Joanne.Olson@Illinois.gov>; Rettig, Todd <Todd.Rettig@Illinois.gov>; Roche, Laura <Laura.Roche@Illinois.Gov>; Kim, John J. <John.J.Kim@Illinois.gov>
Subject: FW: University Park Data

My notes from a phone call with Chris Crockett on public outreach are attached. The phone number below is for customers to request bottled water, a pitcher filter or a lead sample kit. The website is where updates are placed. Chris Crockett said that door hangers and Swifter calls are also used to provide information.

<https://www.waterfactsil.com/>

From: Crockett, Christopher S <CSCrockett@aquaamerica.com>
Sent: Wednesday, June 19, 2019 2:38 PM
To: Cook, David <DAVID.COOK@Illinois.gov>; Sofat, Sanjay <Sanjay.Sofat@Illinois.gov>
Cc: EXT Blanchette, Craig <clblanchette@aquaamerica.com>
Subject: [External] RE: University Park Data

Our phone number to reference calls related to bottled water, lead pitcher filters, and lead sampling is 877.987.2782




Christopher S. Crockett, Ph.D., P.E.
Vice President/Chief Environmental Officer
Aqua America
762 W. Lancaster Ave., Bryn Mawr, PA 19010
O: 610.645.4207 M: 215.850.5304



From: Crockett, Christopher S
Sent: Wednesday, June 19, 2019 6:32 AM
To: Cook, David <DAVID.COOK@Illinois.gov>; Sofat, Sanjay <Sanjay.Sofat@Illinois.gov>
Cc: Blanchette, Craig L <CLBlanchette@aquaamerica.com>
Subject: RE: University Park Data

Please note there is a sample for Personal Address / Ex. 6 That result is suspect as it was from on outside tap that was never used. The lab is rerunning the sample. We visited the property and they use RO in their process. We collected a sample inside the building and are awaiting results.



Christopher S. Crockett, Ph.D., P.E.
Vice President/Chief Environmental Officer
Aqua America
762 W. Lancaster Ave., Bryn Mawr, PA 19010
O: 610.645.4207 M: 215.850.5304



From: Cook, David <DAVID.COOK@Illinois.gov>
Sent: Tuesday, June 18, 2019 9:46 PM
To: Crockett, Christopher S <CSCrockett@aquaamerica.com>; Sofat, Sanjay <Sanjay.Sofat@Illinois.gov>
Cc: Blanchette, Craig L <CLBlanchette@aquaamerica.com>
Subject: Re: University Park Data

Received. Thanks.

From: Crockett, Christopher S <CSCrockett@aquaamerica.com>
Sent: Tuesday, June 18, 2019 7:55:59 PM
To: Sofat, Sanjay; Cook, David
Cc: EXT Blanchette, Craig
Subject: [External] RE: University Park Data

Dear David and Sanjay,



Attached are the updated results as of 5pm today. I would like to note there may have been an address error (ct vs. rd, missing a number). That was fixed in this version.

Also attached are WQP and Ortho results from hydrants today. We expect on collecting results for ortho at homes tomorrow.

I also inserted a map of the areas that were lifted from the DNC. This was based upon the fact that the buildings were post 1990 and representative sampling of the area showed no lead issues.

We are working to produce the maps of piping you requested at our meeting Thursday. Please call me at Personal Phone / Ex. 6 if you have any questions. Please acknowledge that you have been receiving the updates so I can confirm you are getting the information.

Sincerely,
Chris



Christopher S. Crockett, Ph.D., P.E.
Vice President/Chief Environmental Officer
Aqua America

762 W. Lancaster Ave., Bryn Mawr, PA 19010
O: 610.645.4207 M: 215.850.5304



From: Crockett, Christopher S
Sent: Monday, June 17, 2019 11:21 PM
To: sanjay.sofat@illinois.gov; DAVID.COOK@Illinois.gov
Cc: Blanchette, Craig L <CLBlanchette@aquaamerica.com>
Subject: University Park Data

Dear David and Sanjay,

Attached are the results for locations that we had received as of 3pm today. More results came in after 10:30 that we are still compiling into the excel file for the data. I can send you an updated version tomorrow. Please note the samples are broken into several categories. Compliance are true LCR compliance samples for IEPA. Pre flush is a first draw sample collected at a home that is not a true LCR 6 hour stagnation sample and is run with acidification but not the 16 hour acidification (thus dissolved, not total Pb). Post flush is the same as pre flush but we then ran the water for 2 minutes and collected a sample instead of a first draw. The ones labeled "acid" are the same locations but we kept the aliquot of acidified sample for the official 16 hour period and then ran the analysis. The limited data there shows agreement between the dissolved and total results.


Also a map of the areas removed from DNC on 6/16/19 due to the year built, good sample results, and lack of solder plumbing.

This will also change tomorrow with the new results to include a larger area on the west of 48.

Also, I believe Craig Blanchette has already reached out to you about meeting at your offices on Thursday. Now that we've gotten some data and a little time to look at it, we would like to come in and discuss our preliminary findings.

I am also hoping to have our GIS map more easily available of housing stock/age for you by then. Please call me at Personal Phone / Ex. 6 if you have any questions. Kevin, Craig, and Colton are in the field and I am working to be the air traffic controller on our data needs. So please send requests my way so I can track and make sure they are responded to.

Sincerely,
Chris



Christopher S. Crockett, Ph.D., P.E.
Vice President/Chief Environmental Officer
Aqua America

762 W. Lancaster Ave., Bryn Mawr, PA 19010
O: 610.645.4207 M: 215.850.5304



State of Illinois - CONFIDENTIALITY NOTICE: The information contained in this communication is confidential, may be attorney-client privileged or attorney work product, may constitute inside information or internal deliberative staff communication, and is intended only for the use of the addressee. Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify the sender immediately by return e-mail and destroy this communication and all copies thereof, including all attachments. Receipt by an unintended recipient does not waive attorney-client privilege, attorney work product privilege, or any other exemption from disclosure.